



Closed Loop Water Analysis Report

Account Name: MD-021		Customer Name: Jon Miller				
Sample No: 29703	Date Sampled: 5/2/19	Date Received: 5/6/19		Date Completed: 5/13/19		

	Dual Temp Loop					
Color	Light Yellow w/Sediment					
pH	4.8					
Specific Conductance micromhos, 18°C	1436					
Total Iron as Fe, ppm	516					
Copper as Cu, ppm	0.97					
Sodium Nitrite as NaNO ₂ , ppm	220					
Molybdenum as Mo, ppm	<0.02					
Glycol Percent by Volume	N/D					
Freeze Point, °F	-----					
Reserve Alkalinity	-----					
Orthophosphate as PO ₄ , ppm	-----					

Additional Comments:	
N/D = None Detected ----- = Not Tested	

Tests Performed By TH

Approved By TB