

**Additional Funding Request
Corrective Maintenance from PM**

Submitted: 11/13/2018

MD021 – Boiler #1, Boiler #2, Boiler #3, temp gauges	CSS #16296 WO#6439 Asset# 2094
Description of Repairs	S&S hereby proposes to replace gauges for boiler #1, boiler #2 and boiler #3. S&S will provide pictures of pressures and temperature gauges once installed.
Diagnosis: Initial Work Order	Replace altitude gauge on each boiler with pressure on gauge and boiler will pass certification
Explanation of Additional Costs for Repairs	N/A
Investigative Diagnosis from SC	N/A
Additional Material Cost to Perform Repairs	<p>Materials: = \$225.77</p> <p>Gauge/W5702180554/QTY 3 = \$189.78</p> <p>Tax = \$10.99</p> <p>Shipping = \$25.00</p> <p>*Part has 2 week lead time*</p>
Additional Labor Cost to Perform Repairs	<p>Labor:</p> <p>1 HVAC Technician/10hours/ Rate \$100.00 per hour =</p> <p>\$1,000.00</p>
Total of Corrective Maintenance Ticket	\$1,225.77
Minus \$750 – Cost of CM credit	(\$750.00)
Total Cost of Repair	\$475.77