

## Additional Funding Request

Submitted: 1/12/21

<b>MD021 – Compressor not working in OMS Bldg.</b>	<b>CSS #28384 WO# 13454</b>			
Description of Repairs	<p>S&amp;S was onsite and reset contactors and the compressor came on. Once compressor was running we were able to find a leaking ball valve. This leak is causing the compressor to overrun and trip the contactors.</p> <p>S&amp;S proposes to remove and replace the leaking ball valve. S&amp;S will then complete a system check to ensure the compressor is running properly.</p>			
Original SC Investigative Diagnosis	<b>\$300.00</b>			
Diagnosis: Initial Work Order	PD Air Compressor in OMS shop tripped out			
Explanation of Additional Costs for Repairs	N/A			
Additional Material Cost to Perform Repairs	<b>Materials: \$13.48</b>			
	<b>ITEM</b>	<b>QUANTITY</b>	<b>UNIT PRICE</b>	<b>TOTAL</b>
	¾ "Ball Valve	1	\$13.48	\$13.48
Additional Labor Cost to Perform Repairs	<p><b>Labor: \$400.00</b></p> <p>Plumber Labor Tech/4 hours/Rate \$100.00 per hour = \$400.00</p>			
<b>Total Cost of Repair</b>	<b>\$713.48</b>			