

Additional Funding Request

Submitted: **5/10/22**

MD021-Boiler #1 Alarm	CSS #TBD WO#17314											
Description of Repairs	S&S will remove and replace the low water cut off on Boiler # 1. Then, complete a system check to ensure the system is running properly											
Original SC Investigative Diagnosis	NA											
Diagnosis: Initial Work Order	Boiler # 1 is in Alarm, need to have HVAC tech check out the boiler											
Explanation of Additional Costs for Repairs	N/A											
Additional Material Cost to Perform Repairs	<p>Materials: \$</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">ITEM</th> <th style="text-align: left;">QUANTITY</th> <th style="text-align: left;">UNIT PRICE</th> <th style="text-align: left;">TOTAL</th> </tr> </thead> <tbody> <tr> <td>Low Water Cut Off</td> <td style="text-align: center;">1</td> <td style="text-align: center;">\$354.00</td> <td style="text-align: center;">\$354.00</td> </tr> </tbody> </table>				ITEM	QUANTITY	UNIT PRICE	TOTAL	Low Water Cut Off	1	\$354.00	\$354.00
ITEM	QUANTITY	UNIT PRICE	TOTAL									
Low Water Cut Off	1	\$354.00	\$354.00									
Additional Labor Cost to Perform Repairs	<p>Labor: \$600.00 6 hours each/HVAC Rate \$100.00 per hour = \$600.00</p>											
Total Cost of Repair	\$954.00											