

### SERVICE CALL CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID Building: Rockville MD021

Date of Visit: 12/14/18

Contractor Personnel on Site:

1. Patrick Donovan

4. \_\_\_\_\_

2. \_\_\_\_\_

5. \_\_\_\_\_

3. \_\_\_\_\_

6. \_\_\_\_\_

Work Performed:

Service Calls – Service Call Number and Description

1. CSS# 16829 WO# 6884

2. Description of repairs :

found both boilers off and in alarm. Reset  
Gas valves and reset boilers. Watched until both  
boilers cycled.

### CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Donovan

Date: 12/14/18

Signed: [Signature]

To be signed by Facility Manager or Government Official

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name Rank: MSG Jennifer M. Centron

Date: 12/14/18

Signed: [Signature]

E-Mail: jennifer.m.centron.mil@mail.mil