

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Rockville MD 021 Date of Visit: 5/10/19

Contractor Personnel on Site:

1. Patrick Donovan 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 8490, 8521, 8552, 8491, 8522, 8553, AHV's, Dehumidifier, Water Heater Condensing Units, Furnace.

Service Calls – Service Call Number and Description

1. CSS# _____
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Donovan Date: 5/10/19

Signed: Patrick

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Stephen J. Rhoads Date: 5/14/19

Signed: Stephen J. Rhoads

E-Mail: stephen.j.rhoads.civ@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR COOLED CHILLER, PACKAGE UNIT

SITE AND BLDG #: *Rockville MD 20850*

LOCATION/RM #: *Exterior*

WO# *85.21* ASSET # *2100*

MECHANIC SIGNATURE: *[Signature]* DATE: *5/10/19*

START TIME: *8:00* FINISH TIME: *9:15*

ITEM	DESCRIPTION	NOTES
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>
3	Comply with the latest provisions of the Clean Air Act and Environmental Protection Agency (EPA) regulations as they apply to protection of stratospheric ozone.	<input checked="" type="checkbox"/>
4	No intentional venting of refrigerants is permitted. During the servicing, maintenance, and repair of refrigeration equipment, the refrigerant must be recovered.	<input checked="" type="checkbox"/>
5	Whenever refrigerant is added or removed from equipment, record the quantities on the appropriate forms, forms to be maintained by technician in universal waste binder.	<input checked="" type="checkbox"/>
6	Recover, recycle, or reclaim the refrigerant as appropriate.	<input checked="" type="checkbox"/>
7	If disposal of the equipment item is required, follow regulations concerning removal of refrigerants and disposal of the item.	<input checked="" type="checkbox"/>
8	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.	<input checked="" type="checkbox"/>
9	Refrigerant oils to be treated as hazardous waste.	<input checked="" type="checkbox"/>
10	Closely follow all safety procedures described in the Safety Data Sheet (SDS) for the refrigerant and all labels on refrigerant containers.	<input checked="" type="checkbox"/>
11	Remove access covers prior to accomplishing check points.	<input checked="" type="checkbox"/>
1	Remove debris from air screen and clean underneath unit.	<input checked="" type="checkbox"/> <i>Clean</i>
2	Pressure wash coil with proper cleaning solution.	<input checked="" type="checkbox"/> <i>Clean</i>
3	Straighten fin tubes with fin comb.	<input checked="" type="checkbox"/> <i>Clean</i>

4	Check electrical wiring and tighten loose connections. Check fused disconnect switches for condition and operation.	<input checked="" type="checkbox"/>	checked/ good
5	Check mounting for tightness.	<input checked="" type="checkbox"/>	idle/ good
6	Check for corrosion. Clean and treat with inhibitor as needed.	<input checked="" type="checkbox"/>	checked/ good
7	Check fan or blower for bent or damaged blades and imbalance.	<input checked="" type="checkbox"/>	checked/ good
8	Lubricate shaft and motor bearings on fans and remove old or excess lubricant, if applicable.	<input checked="" type="checkbox"/>	checked/ good
9	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multi-belt drives should be replaced with matched sets.	<input checked="" type="checkbox"/>	checked/ good
1	Inspect ex evaporator for any obvious deficiencies.	<input checked="" type="checkbox"/>	checked/ good
2	Inspect plumbing, valves and flanges for leaks and correct as needed.	<input checked="" type="checkbox"/>	checked/ good
1	Lubricate drive coupling, if applicable.	<input checked="" type="checkbox"/>	checked/ good
2	Lubricate motor bearings (non-hermetic), if applicable.	<input checked="" type="checkbox"/>	checked/ good
3	Check bearings for vibrations or unusual noises.	<input checked="" type="checkbox"/>	checked/ good
4	Leak test unit with soap test or electronic device.	<input checked="" type="checkbox"/>	checked/ good
5	Check compressor oil level, if applicable.	<input checked="" type="checkbox"/>	checked/ good
6	Run machine; check action of controls, relays, switches, etc. to see that:		
a	Compressor(s) run at proper settings.	<input checked="" type="checkbox"/>	checked/ good
b	Suction and discharge pressures are proper.	<input checked="" type="checkbox"/>	checked/ good
7	Check vibration eliminators. Replace as necessary.	<input checked="" type="checkbox"/>	checked/ good
8	Check safety controls for high pressure cut off.	<input checked="" type="checkbox"/>	checked/ good
1	Confirm chiller is operating through building automation.	<input checked="" type="checkbox"/>	checked/ good

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Compressor Amp draw: # 1

A) 56.6 B) 53.2 C) 53.1
2 A) 54.8 B) 55.1 C) 55.6

Condenser Amp draw: # 1

A) 47.5 B) 46.1 C) 46.7

A) 44.4 B) 39.7 C) 40.5