

Additional Funding Request

Submitted: 10/29/2020

MD021 – circulation pump	CSS #27242 WO# 12933																
Description of Repairs	new WO#12933 CSS# PENDING > need a proposal for Boiler #1 Circulation pump has bad bearings																
Original SC Investigative Diagnosis																	
Diagnosis: Initial Work Order	S&S proposes to replace the circulation pump for Boiler #1.																
Explanation of Additional Costs for Repairs	N/A																
Additional Material Cost to Perform Repairs	<p>Materials: \$1,228.54</p> <table border="1"> <thead> <tr> <th>ITEM</th><th>QUANTITY</th><th>UNIT PRICE</th><th>TOTAL</th></tr> </thead> <tbody> <tr> <td>Circulation pump</td><td>1</td><td>\$1,228.54</td><td>\$1,228.54</td></tr> <tr> <td></td><td></td><td></td><td></td></tr> <tr> <td></td><td></td><td></td><td></td></tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	Circulation pump	1	\$1,228.54	\$1,228.54								
ITEM	QUANTITY	UNIT PRICE	TOTAL														
Circulation pump	1	\$1,228.54	\$1,228.54														
Additional Labor Cost to Perform Repairs	<p>Labor: \$1,200.00</p> <p>HVAC Labor Tech/12 hours/Rate \$100.00 per hour = \$1,200.00</p>																
Total Cost of Repair	\$2,428.54																