



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	720 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Bldg 1 md024		
Service:	domestic main line		
Make:	Wilkins		
Model:	975XL		
Serial Number:	910054		
Size:	1-1/2"		
Type:	RPZA		

Test Date:	2/6/2020	Test Results:	☒ Pass ☐ Fail
------------	----------	---------------	--

		Comments
Line Pressure:	65	
Shutoff #2 Closed:	☒ Y ☐ N	
CV 1 Closed Tight:	☒ Y ☐ N 10 PSID	
CV 2 Close Tight:	☒ Y ☐ N 4.6 PSID	
RPZ Relief Open:	☒ Y ☐ N 2.0 PSI	
PVB Open:	☐ Y ☐ N PSI	
Air Gap OK?	☒ X ☐ Y ☐ N	

Tester Name:	Brian Douglass	Tester License #:	MD 12654	Gauge Used:	Mid-West 845-5
			WSSC 70369	Serial Number:	10172721
			VA 2717057302	Last Calibration:	10/29/2019



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	700 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Md024		
Service:	Domestic Supply		
Make:	Wilkins		
Model:	975XL		
Serial Number:	910040		
Size:	1-1/2"		
Type:	RPZA		

Test Date: 2/6/2020	Test Results: ☒ Pass ☐ Fail
----------------------------	---

Line Pressure: 65 Shutoff #2 Closed: ☒ Y ☐ N CV 1 Closed Tight: ☒ Y ☐ N 10 PSID CV 2 Close Tight: ☒ Y ☐ N 4.4 PSID RPZ Relief Open: ☒ Y ☐ N 2.0 PSI PVB Open: ☐ Y ☐ N PSI Air Gap OK? X Y ☐ N	Comments
---	---

Tester Name: Brian Douglass	Tester License #: MD 12654 WSSC 70369 VA 2717057302	Gauge Used: Mid-West 845-5 Serial Number: 10172721 Last Calibration: 10/29/2019
------------------------------------	--	--



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	700 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Md024		
Service:	Domestic		
Make:	Wilkins		
Model:	975XL		
Serial Number:	910050		
Size:	1-1/2"		
Type:	RPZA		

Test Date: 2/6/2020	Test Results: ☒ Pass ☐ Fail
----------------------------	---

	Comments
Line Pressure: 65	
Shutoff #2 Closed: ☒ Y ☐ N	
CV 1 Closed Tight: ☒ Y ☐ N 9.2 PSID	
CV 2 Close Tight: ☒ Y ☐ N 4.8 PSID	
RPZ Relief Open: ☒ Y ☐ N 2.0 PSI	
PVB Open: ☐ Y ☐ N PSI	
Air Gap OK? X Y ☐ N	

Tester Name: Brian Douglass	Tester License #: MD 12654 WSSC 70369 VA 2717057302	Gauge Used: Mid-West 845-5 Serial Number: 10172721 Last Calibration: 10/29/2019
------------------------------------	--	--