

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

INSPECTION, TESTING, AND CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 MD024 Date of Visit: 2-5-19

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>John Brown</u> | 4. _____ |
| 2. <u>Charles Brown</u> | 5. _____ |
| 3. _____ | 6. _____ |

Work Performed:


Inspection, Testing, and Certification

- | | | |
|---|------|------|
| 1. Backflow Prevention Testing (Qty 4) (Annual) WO 7194 Asset 1108 | 7198 | 1288 |
| 2. WO 7194 Asset 1109 WO 7195 Asset 1117 WO 7195 Asset 1118 | | |
| 3. <u>7198</u> <u>1289</u> <u>7198</u> <u>1290</u> | | |
| 4. _____ | | |

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Charles R Brown Date: 2-5-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Daniel J. Seymore WS-10 Date: 02/05/19

Signed: 

E-Mail: daniel.j.seymore.civ@vaail.mil



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	720 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement
Location:	Bldg 1 md024
Service::	domestic main line
Make::	Wilkins
Model:	975XL
Serial Number:	910054
Size:	1-1/2"
Type::	RPZA
Asse #:	1013

INITIAL TEST: ☒ Pass ☐ Fail

REPAIR FINAL TEST: ☐ Pass ☐ Fail

INITIAL TEST DATE: 2/5/2019

Final TEST DATE:

Shutoff #2 Close Tight: ☒ Y ☐ N

SHUTOFF #2 CLOSE TIGHT:

CV 1 Close Tight: ☒ Y ☐ N 10 PSID

CHECK #1 CLOSE TIGHT: ☐ Y ☐ N

CV 2 Close Tight: ☒ Y ☐ N 2.6 PSID

CHECK #2 CLOSE TIGHT: ☐ Y ☐ N

RPZ Relief Open: 2.0 PSID

RPZ RELIEF OPEN PSID:

PVB Open: PSID

PVB OPEN PSID:

Line Pressure: 130 PSI

Air Gap OK: ☒ Y ☐ N

Comments

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 10/31/2018



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement
Location:	Md024
Service::	Domestic Supply
Make::	Wilkins
Model:	975XL
Serial Number:	910040
Size:	1-1/2"
Type::	RPZA
Asse #:	1013

INITIAL TEST: ☒ Pass ☐ Fail

REPAIR FINAL TEST: ☐ Pass ☐ Fail

INITIAL TEST DATE: 2/5/2019

Final TEST DATE:

Shutoff #2 Close Tight: ☒ Y ☐ N

SHUTOFF #2 CLOSE TIGHT:

CV 1 Close Tight: ☒ Y ☐ N 9.0 PSID

CHECK #1 CLOSE TIGHT: ☐ Y ☐ N

CV 2 Close Tight: ☒ Y ☐ N 2.2 PSID

CHECK #2 CLOSE TIGHT: ☐ Y ☐ N

RPZ Relief Open: 2.6 PSID

RPZ RELIEF OPEN PSID:

PVB Open: PSID

PVB OPEN PSID:

Line Pressure: 130 PSI

Air Gap OK: ☒ Y ☐ N

Comments

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 10/31/2018



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement
Location:	Md024
Service::	Domestic
Make::	Wilkins
Model:	975XL
Serial Number:	910050
Size:	1-1/2"
Type::	RPZA
Asse #:	1013

INITIAL TEST: ☒ Pass ☐ Fail

REPAIR FINAL TEST: ☐ Pass ☐ Fail

INITIAL TEST DATE: 2/5/2019

Final TEST DATE:

Shutoff #2 Close Tight: ☒ Y ☐ N

SHUTOFF #2 CLOSE TIGHT:

CV 1 Close Tight: ☒ Y ☐ N 8.0 PSID

CHECK #1 CLOSE TIGHT: ☐ Y ☐ N

CV 2 Close Tight: ☒ Y ☐ N 2.0 PSID

CHECK #2 CLOSE TIGHT: ☐ Y ☐ N

RPZ Relief Open: 2.6 PSID

RPZ RELIEF OPEN PSID:

PVB Open: PSID

PVB OPEN PSID:

Line Pressure: 130 PSI

Air Gap OK: ☒ Y ☐ N

Comments

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 10/31/2018





