



# Closed Loop Water Analysis Report

Account Name: MD-03		Customer Name: Jon Miller				
Sample No: 29718	Date Sampled: 5/6/19	Date Received: 5/9/19		Date Completed: 5/17/19		

	Hot Water Loop					
Color	Clear					
pH	8.7					
Specific Conductance micromhos, 18°C	240					
Total Iron as Fe, ppm	0.05					
Copper as Cu, ppm	0.04					
Sodium Nitrite as NaNO <sub>2</sub> , ppm	N/D					
Molybdenum as Mo, ppm	<0.02					
Glycol Percent by Volume	N/D					
Freeze Point, °F	-----					
Reserve Alkalinity	-----					
Orthophosphate as PO <sub>4</sub> , ppm	-----					

## Additional Comments:

N/D = None Detected      ----- = Not Tested

Tests Performed By CC

Approved By TB