

# Water Analysis Report

<b>Account Name:</b> MD-066		<b>Customer Name:</b> Jon Miller	
<b>Sample No:</b> 29704	<b>Date Sampled:</b> 5/2/19	<b>Date Received:</b> 5/6/19	<b>Date Completed:</b> 5/14/19

	Make Up	Tower				
<b>Color</b>	Clear	Clear				
<b>Phenolphthalein Alkalinity as CaCO<sub>3</sub>, ppm</b>	8	24				
<b>Total Alkalinity as CaCO<sub>3</sub>, ppm</b>	124	212				
<b>Chlorides as Cl, ppm</b>	2.4	7.2				
<b>Total Hardness as CaCO<sub>3</sub>, ppm</b>	24	68				
<b>Calcium as CaCO<sub>3</sub>, ppm</b>	16	48				
<b>Magnesium as CaCO<sub>3</sub>, ppm</b>	8	20				
<b>Silica as SiO<sub>2</sub>, ppm</b>	36	78				
<b>Sulfate as SO<sub>4</sub>, ppm</b>	16	29				
<b>pH</b>	8.6	9.0				
<b>Specific Conductance micromhos, 18°C</b>	277	475				
<b>Total Iron as Fe, ppm</b>	0.11	0.11				

## Additional Comments:

N/D = None Detected      ----- = Not Tested

Tests Performed By TH

Approved By TB