



Closed Loop Water Analysis Report

Account Name: MD-066		Customer Name: Jon Miller				
Sample No: 29704	Date Sampled: 5/2/19	Date Received: 5/6/19		Date Completed: 5/14/19		

	Hot Loop					
Color	Orange w/Sediment					
pH	9.1					
Specific Conductance micromhos, 18°C	4334					
Total Iron as Fe, ppm	38					
Copper as Cu, ppm	<0.04					
Sodium Nitrite as NaNO ₂ , ppm	N/D					
Molybdenum as Mo, ppm	167					
Propylene Glycol Percent by Volume	19*					
Freeze Point, °F	+19					
Reserve Alkalinity	22					
Orthophosphate as PO ₄ , ppm	3730					

Additional Comments:

*Glycol type was based on the refractive index cross-reference with specific gravity of the solution.

N/D = None Detected ----- = Not Tested

Tests Performed By TH

Approved By TB