

Tina Lee

From: Richard Hicks
Sent: Saturday, October 30, 2021 10:23 AM
To: Augustin, Kenneth P CIV USARMY 99 RD (USA); Gavin, Jason D CTR USARMY 99 RSC (USA)
Cc: Tina Lee; Devlin, Thomas J CIV USARMY CENAP (US)
Subject: MD066 Boiler certifications are Completed -Boilers are online
Attachments: Carbon Monoxide Sensors WO_13872.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Ken , Team ,

Boilers #1 , 2 , 3 are online for heat . The 3 boilers and water heater passed operational safety testing .

Note : We will not receive boiler certification due to Carbon Monoxide sensors not being installed . The 99th has been provided proposals and have been in discussions for direction to take. WO#13872 -See attached for your records

MD066 USARC White Plains		Fox Tail Place White Plains, MD 20695	
Date	Time	Equipment Type	Manufacturer
10/26/2020	9:00 AM	Closed Heating Loop	Camus
10/26/2020	10:00 AM	Closed Heating Loop	Camus
10/26/2020	11:00 AM	Closed Heating Loop	Camus
10/26/2020	1:00 PM	Closed Heating Loop	Lochinvar

Thanks,
Rick

Rick Hicks
Project Manager Region 5
CMI Management Inc.
5285 Shawnee Road Suite #510
Alexandria,VA 22312
703-738-5301
Richard.Hicks@cmimgmt.com