

## **Additional Funding Request**

Submitted: 11/4/2021

<b>MD066- HVAC System</b>	<b>CSS #32901 WO#15128</b>								
Description of Repairs	S&S proposes to remove and replace the control boards in units 213 & 212. S&S will then complete a system check to ensure everything is running as it should.								
Original SC Investigative Diagnosis	<b>\$150.00</b>								
Diagnosis: Initial Work Order	The HVAC system does not seem to be maintaining the set points in a couple of offices. The thermostat that is located in office 213 also controls 212 and both of these spaces were considerably warmer on my visit on 10/6 than any other spaces I was able to access. I was not able to access the offices on either side of these two offices and am unsure if that thermostat controls any other spaces or not. I would imagine it does.								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p><b>Materials: \$778.62</b></p> <table border="1"> <thead> <tr> <th>ITEM</th> <th>QUANTITY</th> <th>UNIT PRICE</th> <th>TOTAL</th> </tr> </thead> <tbody> <tr> <td><b>Parts/Shipping (Details in quote)</b></td> <td><b>1</b></td> <td><b>\$778.62</b></td> <td><b>\$778.62</b></td> </tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	<b>Parts/Shipping (Details in quote)</b>	<b>1</b>	<b>\$778.62</b>	<b>\$778.62</b>
ITEM	QUANTITY	UNIT PRICE	TOTAL						
<b>Parts/Shipping (Details in quote)</b>	<b>1</b>	<b>\$778.62</b>	<b>\$778.62</b>						
Additional Labor Cost to Perform Repairs	<p><b>Labor: \$900.00</b>  9 hours each/Plumbing Rate \$100.00 per hour = \$900.00</p>								
<b>Total Cost of Repair</b>	<b>\$1,828.62</b>								