

Region: 5

Location: MD066

CSS # 32961

Maximo Work Order No.: 16434

Asset #: NA

Date Issued: 01/10/2022

Original Description: Additional Efforts from WO 15113 (Parking lot lights Asset 373 MEP Lot Parking lot lights Assets 353 & 371)Light head needs replaced.

Repairs Needed:

S&S was able to get all parking lot lights working besides one in the motor pool area near the carpool vans. S&S will need to replace the light head.

RS Means Line Buildup and Labor Summary (Data Version 2017, Q4):

Quantity	Line Item Number	Description	Labor Hours	Labor Rate/Hr	Materials	Equipment	Total
--	NA	DSX2 LEDOK T3S MVOLT RPA	--	--	\$2,307.62	--	\$2,307.62
--	NA	Shipping	--	--	\$200.00	--	\$200.00
--	NA	Lift	2	\$80.00			\$160.00
--	NA	Labor	10	\$100.00	--	--	\$1,000.00

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	Equipment	Total Cost	CE Factor	Total Estimate
10	\$1,000.00	\$2,507.62	\$1,085.47	\$4,593.09	100%	\$4,593.09