

## Additional Funding Request

Submitted: 11/03/2021

<b>MD066-Cooling tower</b>	<b>CSS #30243 WO#14148</b>			
Description of Repairs	S&S will remove and replace the booster pump assembly & motor on the cooling tower. S&S will then complete a system check to ensure everything is running properly.			
Original SC Investigative Diagnosis	<b>\$300.00</b>			
Diagnosis: Initial Work Order	The chemical booster pump located next to the cooling tower is making a grinding sound. Needs to be troubleshot and repaired if needed.			
Explanation of Additional Costs for Repairs	N/A			
Additional Material Cost to Perform Repairs	<b>Materials: \$</b>			
	<b>ITEM</b>	<b>QUANTITY</b>	<b>UNIT PRICE</b>	<b>TOTAL</b>
	<b>Parts/Shipping (Detail in quote)</b>	<b>1</b>	<b>\$1,122.77</b>	<b>\$1,122.77</b>
Additional Labor Cost to Perform Repairs	<b>Labor: \$1000.00</b> 10 hours each/Plumbing Rate \$100.00 per hour = \$1,000.00			
<b>Total Cost of Repair</b>	<b>\$2,422.77</b>			