

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 3/18/22

Contractor Personnel on Site:

- | | |
|-------------------------|------------|
| 1. <u>Patrick Brown</u> | 3. <u></u> |
| 2. <u></u> | 4. <u></u> |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 16323 , 16324 , 16391 , 16392 , 16442-16444 , 16578 ,
2. 16605 , 16325 , 16326 , 16413 , 16445 , 16446
3. ASSET#'S , 10035 , 10036 , 10066 , 10069 , 10046 , 10073 , 10077 ,
4. 10080 , 190917- , 294 , 299 , 278 ,
5.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 3/18/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ABBOTT Date: 3/18/22

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
MAKE UP AIR UNIT - HEATING/COOLING

SITE AND BLDG #: **NY051 BLDG2**
maintenance bay
 LOCATION/RM #: **WO# 16445 ASSET # 10073**

MECHANIC SIGNATURE:  DATE: **3/18/22**
 START TIME: **11am** FINISH TIME: **12pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.	☒	☒	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☒	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check thermostat settings to ensure the cooling and heating systemis operating correctly.	☒	☒	thermostat functions properly
2	Tighten all electrical connections and measure voltage and current on motors.	☒	☒	electrical connections are tight
3	Check filters and clean or replace as necessary.	☒	☒	filters were replaced
4	Lubricate all moving parts.	☒	☒	used white lithium grease
5	Check and inspect the condensate drain in your central air conditioner, furnace and/or heat pump (when in cooling mode).	☒	☒	drain is clear
6	Check controls of the system to ensure proper and safe operation. Check the starting cycle of the equipment to assure the system starts, operates, and shuts off properly.	☒	☒	system functions properly
7	Clean evaporator and condenser air conditioning coils.	☒	☒	coils are clean
8	Clean and adjust blower components to provide proper system airflow.	☒	☒	components are clean
9	Check all gas (or oil) connections, gas pressure, burner combustion and heat exchanger.	☒	☒	gas pressure is correct

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: