

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DOMESTIC HOT WATER HEATER - ELECTRIC

SITE AND BLDG #: NY023-123

LOCATION/RM #: 123

MECHANIC
 SIGNATURE: *John Suthard*

DATE: 11/5/18

START TIME: 12:30pm

FINISH TIME: 1pm

| Site Location | WO # | Asset # | PM # | Manufacturer | Model Number | Serial # | Asset Description | Asset Location |
|---------------|------|---------|------------|--------------|--------------|---------------|--|----------------|
| NY023-123 | 1206 | 9369 | PM-QT-9369 | | PE40M9A | GE 0703D04960 | J-27 1-pc Water Heater Inventory Rm 1020 | |

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---|--|-------------------------------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. | <input checked="" type="checkbox"/> | | |
| 2 | Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | <input checked="" type="checkbox"/> | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Attach drain hose. Drain several gallons from tank to remove sediment. | <input checked="" type="checkbox"/> | | |
| 2 | Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge. | <input checked="" type="checkbox"/> | | |
| 3 | Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters prior to checking connections. | <input checked="" type="checkbox"/> | | |
| 4 | Check operation/ setting of aqua stat. Check hot water temperature with dial thermometer, set aqua stat at minimum value required for all uses. | <input checked="" type="checkbox"/> | | |
| 5 | Check amperage draw of upper and lower elements and compare to name plate data. | <input checked="" type="checkbox"/> | | |

| | | | | |
|---|--|-------------------------------------|--|--|
| 6 | Clean element contacts and check for proper closing under load. | <input checked="" type="checkbox"/> | | |
| 7 | Clean pump, controls, switches, and starters. Check condition of pump seal or packing and replace as required. | <input checked="" type="checkbox"/> | | |
| 8 | If applicable, Remove and inspect Anode, replace if necessary | <input checked="" type="checkbox"/> | | |
| 9 | Clean up work area and remove trash. | <input checked="" type="checkbox"/> | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**