

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 BLDG2 Date of Visit: 10/21/19

Contractor Personnel on Site:

- |                         |          |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 4. _____ |
| 2. _____                | 5. _____ |
| 3. _____                | 6. _____ |

**Service Call Number**

CSS# 21422 WO# 5668


**Description of Repairs**

drained out sewer outside found pump not working and no  
lines that could be snaked further work needs to be done ....  
confined space work ,wiring and pump need to be replaced

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: Patrick Brown Date: 10/21/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: RON VOGT AFOS Date: 10/21/19

Signed: 

E-Mail: \_\_\_\_\_

