

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

THERMOSTATS

SITE AND BLDG #: NY023-118

MECHANIC
SIGNATURE: *Mike Merchan*

DATE: 4/19/19

LOCATION/RM #:

START TIME: 7 am

FINISH TIME: 2 pm

| Site Location | WO # | Asset # | PM # | Manufacturer | Model Number | Serial # | Asset Description | Asset Location |
|---------------|------|---------|------|--------------|--------------|----------|--------------------------------------|----------------|
| NY023-118 | 3285 | 9268 | | Honeywell | | | J-17 2-pc Thermostat, Analog Rm 1011 | |
| NY023-118 | 3286 | 9269 | | Honeywell | | | J-17 4-pc Thermostat, Analog Rm 1005 | |

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) | |
|---|--|---------------|----|---|--|
| | | YES | NO | SPECIAL INSTRUCTIONS | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | | |
| 1 | If EMS (Energy Management System) If it is EMS controlled 1- We log into computer with user name and password for EMS or DDC obtained from site personnel. 2- Validate set point and actual temp at computer | | | | |
| 2 | Review all zone set points at the server IF Applicable | | | | |
| 3 | Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation. | | | | |
| 4 | Remove thermostat cover and lightly blow away any accumulated dust with canned low-pressure air. | | | | |
| 5 | If applicable, replace battery as needed. | | | | |
| 6 | Use our own Temperature meter to validate the computer is correct. If it is not EMS or DDC controlled take our temperature meter and check against actual thermostat and record temperature | | | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

