

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DOMESTIC HOT WATER HEATER - ELECTRIC**

SITE AND BLDG #: NY023-118

LOCATION/RM #: Baker Room

MECHANIC  
SIGNATURE: DEN Rowe

DATE: 3/2/21

START TIME: 11Am

FINISH TIME: 12 pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-118	14189	9279	PM-QT-9279	A O Smith			J-27 1-pc Water Heater Inventory Rm 1007	
NY023-118	14350	190917-151	PMQ190 917151	Rheem	RTGH-95DVLN	M16160 9399	1-pc Water Heater Boiler Room	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/	
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Attach drain hose. Drain several gallons from tank to remove sediment.	✓	/	
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	✓	/	
3	Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters prior to checking connections.	✓	/	

4	Check operation/ setting of aqua stat. Check hot water temperature with dial thermometer, set aqua stat at minimum value required for all uses.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Check amperage draw of upper and lower elements and compare to name plate data.	<input type="checkbox"/>	<input type="checkbox"/>	
6	Clean element contacts and check for proper closing under load.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	Clean pump, controls, switches, and starters. Check condition of pump seal or packing and replace as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
8	If applicable, Remove and inspect Anode, replace if necessary	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
9	Clean up work area and remove trash.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

