

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CONTROL PANEL

ACTIVITY AND BLDG #:NY023-118

LOCATION: Boiler Room

MECHANIC
SIGNATURE: DEEN ROWE

DATE: 9/1/20

START TIME: 8 AM

FINISH TIME: 9 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
	NY023-118	9821	9271	PM-AN-9271	Veeder-Root	TSL-350	J-19 1-pc Fuel Control Panel for Boiler Rm 1011	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check physical condition of the device. a. Shut off power to the unit. b. Blow out the panel with clean, dry air. c. Vacuum any remaining dust d. Turn power back on to the unit.	—	—	
2	Check electrical power connections including incoming line voltage.	—	—	
3	Ensure all electrical wires are in good condition, free of cracking or fraying.	—	—	
4	Check for proper operation of panel.	—	—	

Additional Notes:

This Building No Longer Uses oil burners
 this needs to be removed from PMA checklist.