

# PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

## EXHAUST FANS

**SITE AND BLDG #: NY023-121**

**MECHANIC SIGNATURE:** Deen Rowe **DATE:** 6/7/22

LOCATION/RM #: Building 121

START TIME: 130n FINISH TIME: 11am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel, as needed.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Clean unit, especially fan blades.	✓		
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.	✓		
3	Perform required lubrication and remove old or excess lubricant.	✓		
4	Clean motor with vacuum or low pressure dry air (less than 40 psi). Check for obstructions in motor cooling and air flow.	✓		
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.	✓		
6	Start unit and check for vibration and noise.	✓		
7	Remove all trash and debris.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**