

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

Interior LIGHTING

SITE AND BLDG #: NY023-121

LOCATION/RM #: Building 121

MECHANIC

SIGNATURE: Deen Lowe

DATE: 10/3/22

START TIME: 930 Am

FINISH TIME: 1030 Am

Site Location	WO#	Asset #	Number of lights out	Size, Wattage, and Type	Description	Comments
NY023-121	19271	IL-15			Interior Light in Building NY023-121	
			2	75	Man Vehicle Area	Lift Needed
			6	75	Small Vehicle Area	
			8	75	Gym space (1011)	May be Ballast

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

