

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST GATES

SITE AND BLDG #: NY023-121

MECHANIC
SIGNATURE: Deen Rene

DATE: 12/29/22

LOCATION/RM #: Entrance 121 WO# 20090 ASSET # 9326

START TIME: 8am

FINISH TIME: 830Am

<u>Site Location</u>	<u>WO#</u>	<u>Asset #</u>	<u>PM#</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial #</u>	<u>Asset Description</u>	<u>Asset Location</u>
NY023-121	20090	9326	PM-SA-9326				J-49 1-pc 20 Single Gate, Manual, Sliding East	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
2	Notify affected personnel before performing PM	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	✓		
2	Check all locking devices. Lubricate as required.	✓		
3	Inspect gate support rollers and track, lubricate and clean as required.	✓		
4	Check bolts, fasteners, and mounting hardware. Tighten as necessary.	✓		
5	Check for any obstructions that prevent full swing or movement of the gate.	✓		
6	Check that shrubs and trees are pruned clear of gate.	✓		
7	Check hold open devices for proper operation. Lubricate as required.	✓		

8	Check the top guard and ensure that it is properly fastened and the wires are tight. Tighten as required.	✓		
9	If applicable, inspect hydraulic driveline (hoses, fittings, and gauges) for signs of leakage.	N	A	
10	If applicable, inspect limit switches for proper operation. Adjust as needed.	N	A	
11	If applicable, inspect photoeyes for proper operation and any signs of damage.	N	A	
12	If applicable, have site personnel operate gate with CAC Card insuring proper operation.	N	A	
13	If applicable, clean control cabinet, ensuring free from debris and insects.	N	A	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

Additional Notes: