

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

### EXHAUST BLOWER/CONNECTION

**SITE AND BLDG #:** NY023-121

**MECHANIC**

**SIGNATURE:** *Signature on File (Rodon)*

**DATE:** 9/6/2023

**LOCATION/RM #:** Building 121

**START TIME:**

**FINISH TIME:**

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-121	<b>24084</b>	9333	PM-QT-9333				J-57 1-pc Exhaust Blower	
NY023-121	<b>24085</b>	9334	PM-QT-9334				J-57 5-pc Exhaust Connection	
NY023-121	<b>24086</b>	9335	PM-QT-9335				J-57 1-pc Exhaust Blower	
NY023-121	<b>24087</b>	9336	PM-QT-9336				J-57 6-pc Exhaust Connection	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS	
		YES	NO	1 TASK COMPLETE IS CHECKED NO PROVIDE EXPLANATION	
SPECIAL INSTRUCTIONS					
	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X			
2	Schedule shutdown with operating personnel, as needed.	X			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
	Clean unit, especially fan blades.	X			
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.	X			
3	Perform required lubrication and remove old or excess lubricant.	X			

4	Clean motor with vacuum or low pressure dry air (less than 40 psi). Check for obstructions in motor cooling and air flow.	<input checked="" type="checkbox"/>		
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.	<input checked="" type="checkbox"/>		
6	Start unit and check for vibration and noise.	<input checked="" type="checkbox"/>		
7	Remove all trash and debris.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**