

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: NY023-121

LOCATION/RM #: Building 121 garage

MECHANIC

SIGNATURE: Mike Wolfe

DATE: 11 / 11 / 19

START TIME: 8 Am

FINISH TIME: 10 Am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-121	6230	9333	PM-QT-9333				J-57 1-pc Exhaust Blower	
NY023-121	6231	9334	PM-QT-9334				J-57 5-pc Exhaust Connection	
NY023-121	6232	9335	PM-QT-9335				J-57 1-pc Exhaust Blower	
NY023-121	6233	9336	PM-QT-9336				J-57 6-pc Exhaust Connection	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
SPECIAL INSTRUCTIONS					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Start and stop fan with local switch		<input checked="" type="checkbox"/>		
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.		<input checked="" type="checkbox"/>		
3	Inspect, adjust belts and pulleys. Replace belt as needed.		<input checked="" type="checkbox"/>		

4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
6	Clean fan as needed.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
8	Repair as needed		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



Too high to service
these units.