

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR CONDITIONER - PACKAGE UNIT

ACTIVITY AND BLDG #: NY023-123

MECHANIC
 SIGNATURE: *Deewi Rose*

DATE: *6/4/21*LOCATION: *B. 123*START TIME: *9Am*FINISH TIME: *12pm*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-123	12878	190917-164	PFQ190917164	Trane	4tta304804000ca	14334pnd3f	1-pc AC Units	
NY023-123	12878	190917-165	PFQ190917164	Trane	4tta304804000ca	16171ch3f	1-pc AC Units	
NY023-123	12878	190917-166	PFQ190917164	Trane	4tta304804000ca	14515muc3f	1-pc AC Units	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Verify Filter Condition. If clogged prior to scheduled change, change filter immediately. Label date on all filter installations.	✓		
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	✓		
3	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		
4	Inspect, adjust belts and pulleys. Replace belt as needed.	✓		
5	Clean dampers, louvers, or shutters; lubricate pivot points and inspect linkages for tightness.	✓		
6	Clean evaporator coils. Use cleaning solvent that is approved by equipment manufacturer. Clean blower wheels when coils are cleaned.	✓		
7	Clean condenser coils and straighten fins as required. Use cleaning solvent that is approved by equipment manufacturer.	✓		

9	Inspect for tightness of connection to duckwork.	<input checked="" type="checkbox"/>		
10	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit	<input checked="" type="checkbox"/>		
11	Inspect piping and valves for leaks and tighten loose connections.	<input checked="" type="checkbox"/>		
12	Inspect mounting brackets, bolts, fan guards, etc., adjust and tighten as required.	<input checked="" type="checkbox"/>		
13	Check all structural components; tighten bolts, nuts, and supports as required.	<input checked="" type="checkbox"/>		
14	Inspect for rust and corrosion. Apply paint where applicable.	<input checked="" type="checkbox"/>		
15	Inspect for waterlogged, loose, torn, or missing insulation. Repair as needed.	<input checked="" type="checkbox"/>		
16	Check the drain pan and condensate piping for blockages. Remove if found. Add treatment to prevent fungus growth. Clean drain pan.	<input checked="" type="checkbox"/>		
17	Inspect controls and unit for proper operation.	<input checked="" type="checkbox"/>		
18	Inspect unit for overall condition and recommend for replacement or other needed repairs.	<input checked="" type="checkbox"/>		
19	Check compressor oil levels and/or pressure on refrigerant systems having oil level and/or pressure measurement means. Repair, replace, or adjust as needed to ensure proper operation. If a leak is suspected, check all piping and connections for leaks.	<input checked="" type="checkbox"/>		
20	Check refrigerant system temperatures. If outside of recommended levels, find cause, repair, and adjust refrigerant charge to achieve optimal operating levels.	<input checked="" type="checkbox"/>		
21	Check oil level, add oil as required	<input checked="" type="checkbox"/>		
8	Clean heat wheel using soap and water.	<input checked="" type="checkbox"/>		

