

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CIRCULATING AND BOOSTER PUMPS

SITE AND BLDG #: NY023-123

MECHANIC
SIGNATURE: *Deen Rowe*

DATE: *8/3/21*

LOCATION/RM #: *Boiler Room*

START TIME: *8am*

FINISH TIME: *9am*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-123	14367	190917-154	PMS190 917154	Reliance	em3313t	f130642560	1-pc HW Pump Boiler Room	
NY023-123	14367	190917-155	PMS190 917154	Reliance	em3313t	f1306042535	1-pc HW Pump Boiler Room	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				

1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication at least annually.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Inspect couplings and check for any pump seal leaks.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Check motor mounts and vibration pads	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Tighten all pump flanges.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Visually check pump alignment and coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Inspect electrical connections	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

