

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR HANDLER

SITE AND BLDG #: NY023-123

**MECHANIC
SIGNATURE:** DEEN ROWE

DATE: 9/3/21

LOCATION/RM #: Comms Room / Arms Room

START TIME: 8 AM

FINISH TIME: 10 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-123	14579	9337	PM-FQT-9337	Carrier			J-04 1-pc Air Handler	
NY023-123	14772	9337	PM-SA-9337	Carrier			J-04 1-pc Air Handler	

BELT SIZE

QTY

N/A

FILTER SIZE

QTY

Washable Filter

2

Make, Model and Serial number must be filled out and corrected if applicable.

Before and After Pictures Required

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Check/Lubricate blower and motor bearings	✓	/	
2	Check operating voltage-indicate voltage in note section	✓	/	208/230 ✓
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check amperage-indicate voltage in note section	✓	/	

2	Visually check control valve(s)	✓		_____
3	Check operation of control valve(s)	✓		
4	Check condition of coils	✓		
5	Visually inspect for coil leaks	✓		
6	Visually inspect for piping leaks	✓		
7	Check for deterioration of gaskets	✓		
8	Record differential temperatures	✓		
9	Record differential pressures	✓		
10	Check starter/contactor	✓		
11	Check and tighten electrical connections	✓		
12	Clean condensate pan and clear drain line	✓		
13	Check overall condition of unit- include year of model in note section	✓		

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
14	Inspect and Change belt if needed- indicate size in note section	N	A	
15	Change filter- indicate size in note section	✓		Cleaned Filters
16	Check integrity of cabinet hardware	✓		
17	Inspect motor mounting isolators	✓		
18	Check condition of pulley and belts	N	A	
19	Check pulley alignment	N	A	

20	Remove and dispose of any debris from any maintenance activity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
21	Document tasks performed during visit and report any observations to supervisor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

