

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: NY023-123

MECHANIC
SIGNATURE: *Deen Rose*

DATE: *3/23/22*

LOCATION/RM #: *Boiler Room*

START TIME: *10Am*

FINISH TIME: *1030 Am*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-123	18588	190917-156	PMQ190 917153	TACO		369755	1-pc Expansion Tank	
NY023-123	18588	190917-157	PMQ190 917153	Amstrol			1-pc Expansion Tank	
NY023-123	18588	190917-158	PMQ190 917153	TACO		357720	1-pc Expansion Tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓	/	
2	Test air pressure in tank. Ensure air pressure is at correct PSI. Correct as needed.	✓	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

* Asset # 190917-157 Psi is 74.5 / 150

* Asset # 190917-156 Psi is 36 / 125