

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER

SITE AND BLDG #: NY023-123

**MECHANIC
SIGNATURE:**

Deen Rowe

DATE: 12/17/16

LOCATION/RM #: Vehicle Area

START TIME: 9am

FINISH TIME: 9am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-123	6372	9341	PM-SA-9341				J-08 5-pc Unit Heater, Hot Water	
NY023-123	6373	9342	PM-SA-9342				J-08 2-pc Unit Heater, Hot Water	
NY023-123	6374	9343	PM-SA-9343				J-08 3-pc Unit Heater, Hot Water	
NY023-123	6375	9344	PM-SA-9344				J-08 5-pc Unit Heater, Hot Water	
NY023-123	6376	9345	PM-SA-9345				J-08 3-pc Unit Heater, Hot Water	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		<input checked="" type="checkbox"/>	
2	Schedule shutdown with operating personnel.		<input checked="" type="checkbox"/>	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		<input checked="" type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.		<input checked="" type="checkbox"/>	

2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.		✓	
3	Clean the coil with vacuum cleaner.		✓	
4	Comb the fins as needed.		✓	
5	Clean all fans and motors.		✓	
6	Check operation of controls and safeties.		✓	
7	Lubricate as required.		✓	
8	Check all motors, belts, pulleys, shafts, etc. for alignment.		✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

Units are too high to service

