

WO 11058

**Annual Exit & Emergency  
Lighting Inspection****FAC ID: N4023****BLDG NO: 124****INSPECTION DATE: 12/03/20**

- Individual Battery-Powered Lighting Units: Activate not less than 90 minutes
- Central Battery Powered Lighting Systems: Activate not less than 90 minutes
- Emergency Generator-Powered Lighting Systems: During regularly scheduled generator and transfer switch maintenance, visually check operation of each emergency generator-powered fixture.

#	Location	Type	Battery Type	Pass/Fail
1	Entrance / Exit	12v 9AH	Individual Battery - Powered	Pass
2	Entrance / Exit	12v 9AH	Individual Battery - Powered	Pass
3	Back Wall	12v 9AH	Individual Battery - Powered	PASS
4	Bathroom	12v 9AH	Individual Battery - Powered	FAIL
5	Cages	12v 9AH	Individual Battery - Powered	Pass
6	Cages	12v 9AH	Individual Battery - Powered	Pass
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				

I confirm the devices listed above has been inspected and tested per NFPA and UFC guidance: 

Notes: Replaced Battery for the Bathroom Emergency Light. (12v 9AH)