

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PLUMBING FIXTURES

ACTIVITY AND BLDG #: NY023-124

LOCATION: *Bathroom*MECHANIC
SIGNATURE: *Deen Rowe*DATE: *7/7/21*START TIME: *8 am*FINISH TIME: *8 am*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-124	13651	9393	PM-AN-9393				J-26 2-pc Toilet, Flush Valve, Wall Mounted Rm 1005	
NY023-124	13652	9394	PM-AN-9394				J-26 2-pc Lavatory, Wall Mounted Rm 1005	
NY023-124	13653	9395	PM-AN-9395				J-26 1-pc Toilet, Flush Valve, Wall Mounted Rm 1006	
NY023-124	13654	9396	PM-AN-9396				J-26 1-pc Urinal, Wet, Flush Valve Rm 1006	
NY023-124	13655	9397	PM-AN-9397				J-26 2-pc Lavatory, Wall Mounted Rm 1006	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
SPECIAL INSTRUCTIONS					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<i>—</i>	<i>—</i>		
2	Review manufacturer's instructions.	<i>—</i>	<i>—</i>		

3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	—	—	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	SINKS - Operate faucets, inspect for leaks, replace washers/"O" rings as necessary. Observe drain flow, clean trap if obstructed. Replace filter as needed.	—	—	
2	SHOWER HEADS, MIXING VALVES - Check shower for damaged, missing, or leaking heads; replace as required. Check mixing valves for damaged or missing parts; replace washers as needed.	—	—	
3	SHOWER STALLS - Check for leaks, cracks, significant wear or vandalism.	—	—	
4	TOILETS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps, seat supports, and replace.	—	—	
5	URINALS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps and replace.	—	—	
6	OTHER MISCELLANEOUS FIXTURES - Clean and inspect for any damage. Check for leaks, missing or damaged parts, caps, etc. Replace as needed.	—	—	

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM
 Checklist compiled in accordance with:

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at ([Provide Link](#))

Additional Notes:



Page 1 of 1

- * Bathrooms Are locked because this Building is not occupied.
- * No water in The Building.