

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER

SITE AND BLDG #: NY023-128

MECHANIC
SIGNATURE: *Deen Rowe*

DATE: 2/15/21

LOCATION/RM #: Boiler Room

START TIME: 1130am

FINISH TIME: 12pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-128	16137	9419	PM-QT-9419	GE	GE40M06AAG	GE 0805B35873	J-27 1-pc Water Heater Inventory Rm A004	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.	N	A	
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	N	A	

3	Clean the coil with vacuum cleaner.	N	A	
4	Comb the fins as needed.	N	A	
5	Clean all fans and motors.	N	A	
6	Check operation of controls and safeties.	N	A	
7	Lubricate as required.	N	A	
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	N	PR	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

- * This is for a unit heater wing checklist (Hot water tank)
- * Check thermostat and hot water coil.

