

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
KITCHEN RANGE HOOD

ACTIVITY AND BLDG #: NY023-200

MECHANIC
SIGNATURE:

DATE:

LOCATION:

START TIME:

FINISH TIME:

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-200	4046	9488					J-38 1-pc Kitchen Hood	
NY023-200	4047	9489					J-38 2-pc Kitchen Hood	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Review manufacturer's instructions.			
3	always Follow lock out/tag out procedures . De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove filters, scrape and wash plenum walls, filter frames and fire suppression equipment (not including the fusible links and trigger mechanisms).			
2	Scrape and/or brush the interior surfaces of all accessible horizontal and vertical ductwork.			
3	Wash all fan blades, interior and exterior of fan housing and drip pans (hot, high pressure wash when possible).			
4	Clean all louvers and dampers. If dampers must be moved to ensure complete cleaning, they will be marked and returned to their original position to prevent unbalancing the system.			
5	Replace filters to their original position			



Page 1 of 1