

Annual Exit & Emergency Lighting Inspection

FAC ID: NY023-200

BLDG NO: 200

INSPECTION DATE: 11/15/19

- Individual Battery-Powered Lighting Units: Activate not less than 90 minutes
- Central Battery Powered Lighting Systems: Activate not less than 90 minutes
- Emergency Generator-Powered Lighting Systems: During regularly scheduled generator and transfer switch maintenance, visually check operation of each emergency generator-powered fixture.

#	Location	Type	Battery Type	Pass/Fail
1	Near Rm 3013 Double Light wall Pak		Rechargeable lead acid PE6V12FL	6V 12AH
2	Near Rm 3004 Double Light wall Pak		6V 12AH	
3	JV Stairwell B Double Light wall Pak		6V 12AH	
4	Near Rm 2002 Double Light wall Pak		6V 12AH	
5	Near Rm 2016 Double Light wall Pak		6V 12AH	
6	Near 2nd Floor Elevator Double Light wall Pak		6V 12AH	
7	Near Rm 2034 Double Light wall Pak		6V 12AH	
8	Staircase by Cages Double Light wall Pak		6V 12AH	
9	Near Rm 2026 Double Light wall Pak		6V 12AH	
10	2nd Floor Above Locker 1902 Double Light wall Pak		6V 12AH	
11	Near Rm 2034 Double Light wall Pak		6V 12AH	
12	12th Floor By Elevator Double Light wall Pak		6V 12AH	
13	15th Floor By Linchpin Rm 1032 Double Light wall Pak		6V 12AH	
14	1st Floor By 1022 Double Light wall Pak		6V 12AH	
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				

I confirm the devices listed above has been inspected and tested per NFPA and UFC guidance:

☐

Notes: