

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: NY023-206

MECHANIC
 SIGNATURE: *Mike Wolfe*

DATE: 9/13/19

LOCATION/RM #: **WO# 5202**

START TIME: 7am

FINISH TIME: 2 PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	✓	✓	
2	Initial and Date Filter (if disposable)	✓	✓	
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓	✓	
ASSET #	SIZE	QTY	NOTES/ ACTIONS	
9497				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes:



Page 1 of 1

