

PREVENTIVE MAINTENANCE PROGRAM CHECKLIST

FILTER CHANGE ONLY

SITE AND BLDG#:NY023-206

MECHANIC
SIGNATURE:SIGNATURE ON FILE (null)

DATE:

Site Location	WO#	Asset#	PM#	Manufacturer	Model Number	Serial#	Asset Description	Asset Location
NY023-206	2-23947		PM-FQT-9497					

CHECK POINT	CHECKPOINT DESCRIPTION	NOTES/ACTIONS (if Task Complete is Checked 'NO', Then Provide Explanation)
TO BE PERFORMED AT EACH INSPECTION SERVICE		
	Change filter	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by:General Maintenance Worker

Additional Notes: