

**Annual Exit & Emergency
Lighting Inspection****FAC ID: NY-023**
BLDG NO: #319
INSPECTION DATE: 12/20/19

- Individual Battery-Powered Lighting Units: Activate not less than 90 minutes
- Central Battery Powered Lighting Systems: Activate not less than 90 minutes
- Emergency Generator-Powered Lighting Systems: During regularly scheduled generator and transfer switch maintenance, visually check operation of each emergency generator-powered fixture.

WO 6439

#	Location	Type	Battery Type	Pass/Fail
1	Replaced 10 Batteries on 1 st Floor and Basement Changed 2 Bulbs		6V - 4.5 AH	✓
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				

I confirm the devices listed above has been inspected and tested per NFPA and UFC guidance:



Notes: