

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
DOOR KEYPAD / CARD READER**

SITE AND BLDG #: NY023-330

LOCATION/RM #:

MECHANIC  
SIGNATURE:

*crinke waelz*

DATE:

*7/1/19*

START TIME:

*7am*

FINISH TIME:

*2pm*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-330	4679	9605					J-54 2-pc Key Punch Pad	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If applicable, test the controls for communications to the monitoring center. Inspect key pad for sticking keys and LED lights proper operation.			
2	Check power supplies. Clean keys and pad with a quick dry electrical cleaner. Wipe unit down			
3	Inspect and test the operation of device. -Observe unit in use			
4	Ensure proper protection of all visible wiring and conduits			

5	Verify that no compromise to devices has occurred (compromise of devices could be from building alterations, partitions, furniture or other obstacles) Any deficiencies found open a CM work order in Maximo and quote will be provided for CM repairs. Notate in note Column			
---	--	--	--	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

