

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES

SITE AND BLDG #: NY023-330

MECHANIC
SIGNATURE: Deen Rane

DATE: 12/14/21LOCATION/RM #: Entrance/ExitASSET #START TIME: 3:30 pmFINISH TIME: 4 pm

<u>Site Location</u>	<u>WO#</u>	<u>Asset #</u>	<u>PM#</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial #</u>	<u>Asset Description</u>	<u>Asset Location</u>
NY023-330	15457	9601	PM-SA-9601				J-49 1-pc Single Gate, Manual, Sliding Perimeter	
NY023-330	15458	9602	PM-SA-9602				J-49 1-pc Single Gate, Manual, Sliding Perimeter	
NY023-330	15459	9603	PM-SA-9603				J-49 1-pc Single Gate, Manual, Sliding Rm A bldg entrance	
NY023-330	15460	9604	PM-SA-9604				J-49 1-pc Single Gate, Manual, Sliding B bldg entrance	

<u>CHECK POINT</u>	<u>CHECKPOINT DESCRIPTION</u>	<u>TASK COMPLETE</u>		<u>NOTES/ ACTIONS</u>	
		<u>YES</u>	<u>NO</u>	(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
SPECIAL INSTRUCTIONS					

1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Notify affected personnel before performing PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Check all locking devices. Lubricate as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Inspect gate support rollers and track, lubricate and clean as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Check bolts, fasteners, and mounting hardware. Tighten as necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Check for any obstructions that prevent full swing or movement of the gate.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Check that shrubs and trees are pruned clear of gate.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	Check hold open devices for proper operation. Lubricate as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
8	Check the top guard and ensure that it is properly fastened and the wires are tight. Tighten as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
9	If applicable, inspect hydraulic driveline (hoses, fittings, and gauges) for signs of leakage.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
10	If applicable, inspect limit switches for proper operation. Adjust as needed.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
11	If applicable, inspect photoeyes for proper operation and any signs of damage.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
12	If applicable, have site personnel operate gate with CAC Card insuring proper operation.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
13	If applicable, clean control cabinet, ensuring free from debris and insects.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Page 1 of 1

