

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR HANDLER

SITE AND BLDG #: NY023-330

**MECHANIC
SIGNATURE:**

Deen Lowe

DATE: 3/16/23

LOCATION/RM #: Attic A/B

START TIME: 8am

FINISH TIME: 4pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14896	1-pc AHU	
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14903	1-pc AHU	
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14855	1-pc AHU	
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u15459	1-pc AHU	
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14856	1-pc AHU	
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14854	1-pc AHU	
NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14858	1-pc AHU	

NY023-330	21087	Carrier	4druaa08a2a6-oaad	Carrier	4druaa08a2a6-oaad	2815u14902	1-pc AHU	
NY023-330	21432	190917-203	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14896	1-pc AHU	
NY023-330	21432	190917-204	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14903	1-pc AHU	
NY023-330	21432	190917-205	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14855	1-pc AHU	
NY023-330	21432	190917-206	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u15459	1-pc AHU	
NY023-330	21432	190917-207	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14856	1-pc AHU	
NY023-330	21432	190917-208	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14854	1-pc AHU	
NY023-330	21432	190917-209	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14858	1-pc AHU	
NY023-330	21432	190917-210	PMS190917203	Carrier	4druaa08a2a6-oaad	2815u14902	1-pc AHU	

BELT SIZE	QTY
A-39	1 EACH
FILTER SIZE	QTY
16X24X2	4 EACH

Make, Model and Serial number must be filled out and corrected if applicable.

Before and After Pictures Required

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Check/Lubricate blower and motor bearings	✓	/	
2	Check operating voltage- indicate voltage in note section	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check amperage- indicate voltage in note section	✓	/	
2	Visually check control valve(s)	✓	/	
3	Check operation of control valve(s)	✓	/	
4	Check condition of coils	✓	/	
5	Visually inspect for coil leaks	✓	/	
6	Visually inspect for piping leaks	✓	/	
7	Check for deterioration of gaskets	✓	/	
8	Record differential temperatures	✓	/	
9	Record differential pressures	✓	/	
10	Check starter/contactors	✓	/	
11	Check and tighten electrical connections	✓	/	
12	Clean condensate pan and clear drain line	✓	/	
13	Check overall condition of unit- include year of model in note section	✓	/	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	

14	Inspect and Change belt if needed- indicate size in note section	✓		
15	Change filter- indicate size in note section	✓		
16	Check integrity of cabinet hardware	✓		
17	Inspect motor mounting isolators	✓		
18	Check condition of pulley and belts	✓		
19	Check pulley alignment	✓		
20	Remove and dispose of any debris from any maintenance activity	✓		
21	Document tasks performed during visit and report any observations to supervisor	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

