

GALAXY LOCK & ALARM, INC.

3633 E. Tremont Ave
Bronx, New York 10465



718-863-1365

D Work Order

Date	Work Order #
09/2/2020	15618

NYC LIC # 790359

Bill To:

Accounts Payable
International Support Group 118
9050 Pines Blvd, Suite 150

Pembroke, FL 33024

Job Site or Ship To:

U.S Army ReserveCenter
Fort Totten
118 Duane Road
Fort Totten, NY 11359
954-900-1095x1006

P.O. Number:

Rep: Carl

Requested By: Michelle Dubois

WORK COMPLETED AND/OR MATERIAL DELIVERED	QTY
Vault room 1035A with Mosler not GSA one hour fire rated vault door	
Vault room 1039 with Diebold by Mosler red label 5A armory door.	
Perform PMInspection. See attached report.	
Replace 12VDC 7A battery in alarm panel in room 1035A.	

SIGNATURE: 

PRINT NAME: Ryan Linn

I hereby acknowledge the satisfactory delivery and completion of the above described work.

This is your receipt for material and/or services completed.
Your invoice will be sent to your accounts payable department.



E-mail: galaxylock@optonline.net

Website: www.galaxylock.com

GSA SAFE & VAULT INSPECTION CHECK LIST**DATE: 9/16/20** **MAKE: MOSEL****MODEL: FIRE RATED** **SERIAL # 142933****AGENCY: USAR NY023****ADDRESS: 200 DURKEE ROAD, PAYKIDE, NY****CHECK OPERATION AND TIGHTNESS OF ITEMS LISTED BELOW.****LIST ANY COMMENTS IN THE SPACE PROVIDED.****PLACE CHECK MARK NEXT TO ITEM NUMBER IF FUNCTION OK.**

- 1. DIAL COMBINATION, CHECK TOLERANCE X-1/0
- 2. DIAL FREEDOM TO TURN
- 3. DIAL RING SECURITY
- 4. COMBINATION LOCK COVER SCREWS
- 5. COMBINATION LOCK LEVER SCREW (W/UNJELLED MISC/M-UNJELLED FOR ME)
- 6. COMBINATION LOCK MOUNT SCREWS
- 7. COMBINATION LOCK SPLINE KEY, SPINDLE NUT, OR SCREW
- 8. COMBINATION LOCK DIAL HUB TO SPINDLE SLIPPAGE
- 9. COMBINATION LOCK BOLT EXTENSION MOUNT SCREWS
- 10. EXTERIOR BOLT/WORK HANDLE FOR PLAY
- 11. INTERIOR BOLT/WORK HANDLE FOR PLAY
- 12. BOLT/WORK DETENT-HOLD BACK MECHANISM
- 13. EMERGENCY ESCAPE MECHANISM OPERATION (MUST END THIS MODE)
- 14. BOLT MECHANISM LINKAGES FOR KEY PRESENT AND OPERATING
- 15. BOLT MECHANISM LINKAGES FOR KEY PRESENT AND OPERATING (REMOVE DOOR PANEL)
- 16. LUBRICATE BOLT LINKAGES AS NECESSARY
- 17. SAFE DOOR CLEARANCE TO FRAME
- 18. SAFE DOOR LEVEL AND PLUMB (NO DRIFT)

① VAULT DOOR AND FRAME NOT APPROVED COLOR ON EXTERIOR
② COMBINATION LOCK NOT APPROVED FOR AAA STORAGE

Cc6.20

#15618
Army ReserveCenter Fort Totten 118 Duane Road Fort Totten, NY 11359
2/2020 2:50 PM
Army Lock & Alarm Inc.

2/2020 2:50 PM
Army Lock & Alarm Inc.

GSA SAFE & VAULT INSPECTION CHECK LIST**DATE: 9/16/20** **MAKE: DEDBOLD/MOSEL****MODEL: DEDBOLD** **SERIAL # 365-0804 (04/16/10)****AGENCY: USAR NY023****ADDRESS: 200 DURKEE ROAD, PAYKIDE, NY****CHECK OPERATION AND TIGHTNESS OF ITEMS LISTED BELOW.****PLACE CHECK MARK NEXT TO ITEM NUMBER IF FUNCTION OK.**

- 1. DIAL COMBINATION, CHECK TOLERANCE ±1/6-3/7
- 2. DIAL FREEDOM TO TURN
- 3. DIAL RING SECURITY
- 4. COMBINATION LOCK COVER SCREWS
- 5. COMBINATION LOCK LEVER SCREW
- 6. COMBINATION LOCK MOUNT SCREWS
- 7. COMBINATION LOCK SPLINE KEY, SPINDLE NUT, OR SCREW
- 8. COMBINATION LOCK BOLT EXTENSION MOUNT SCREWS
- 9. COMBINATION LOCK DIAL HUB TO SPINDLE SLIPPAGE
- 10. EXTERIOR BOLT/WORK HANDLE FOR PLAY
- 11. INTERIOR BOLT/WORK HANDLE FOR PLAY
- 12. BOLT/WORK DETENT-HOLD BACK MECHANISM
- 13. EMERGENCY ESCAPE MECHANISM OPERATION
- 14. BOLT MECHANISM LINKAGES FOR KEY PRESENT AND OPERATING
- 15. BOLT MECHANISM LINKAGES FOR KEY PRESENT AND OPERATING (REMOVE DOOR PANEL)
- 16. LUBRICATE BOLT LINKAGES AS NECESSARY
- 17. SAFE DOOR CLEARANCE TO FRAME
- 18. SAFE DOOR LEVEL AND PLUMB (NO DRIFT)

Cc6.20

#15618
Army ReserveCenter Fort Totten 118 Duane Road Fort Totten, NY 11359
2/2020 2:59 PM
Army Lock & Alarm Inc.