

Additional Funding Request

Site: NY023	WO# 3177	CSS # 17679	Asset# NA
Description of Repairs	Need to replace expansion tank		
Diagnosis: Initial Work Order CSS# 17679	Sent over Ryan Linn, repair expansion tank and pressure release valve for domestic water heaters		
Explanation of Additional Costs for Repairs	Labor and material to replace expansion tank		
Additional Labor Cost to Perform Repairs	4 x \$102= \$408.00 Admin Fee- \$146.20		
Additional Material Cost to Perform Repairs	\$323.00		
Total Cost of Repair	\$877.20		

ACAV SERVICES

March 11, 2019



ESTIMATE 0309192 CSS 17679

Bill To		Ship To	
Customer	International Support Group M Wolfe	Recipient	99 RSC DPW R Linn
Customer ID#	[Customer ID]	Address	Ernie Pyle USARC BLDG 200 Ft Totten NY
Address	9050 Pines Blvd STE 150 Pembroke Pines FL 33024	Phone	718 631 6188
Phone	718 790 3562		
Payment Due	NET 30	Delivery Date	March 29, 2019
Salesperson	JW	Shipping Method	N/A
Payment Terms	CC	Shipping Terms	N/A

Qty.	Item#	Description	Unit Price	Line Total
1	1	<p>BLDG 200 Main Boiler Room</p> <p>Remove and replace one 15 Gal expansion tank with a EX30 AMTROL (30 Gal) or equivalent expansion tank on the hot water system</p> <p>Material Cost</p> <p>Labor Cost 4 Hours 102.00 per hour (2 men)</p> <p>NO TAX</p> <p>Admin Fee 20%</p> <p>TOTAL</p>		

ACAV Services

11 Snug Cove Lane
Bayville NY 11709
Jacka377@verizon.net
516 941 6581

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: W4013 Bldg 200

Date of Visit: 3/9/18

Contractor Personnel on Site:

1. S Shaded

2. O VESO TWOHRLE

Work Performed:

Preventive Maintenance -(Annual, Quarterly, Monthly, equipment identification, etc.)
Service Orders -

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: JOHN WOHM Date: 3/9/19

Signed: pm

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Louis Corbo Date: 3/9/19

Signed: Louis Corbo

E-Mail: Louis.A.Corbo.CTR@mail.mil



1/4" x 2 1/2"

 Live Chat

Share

Save to Favorites

Print



Amtrol

EX-30 Expansion Tank Air Eliminator Kit

★★★★★ (1) Write a Review Ask the first question

\$269⁶⁹

Quantity

Not in Your Store - We'll Ship It There

Available for pickup
March 27 - March 29

We'll send it to Jericho for free pickup



CASH ACME

T/TV Series Thermal Expansion Tank

3406 7th Avenue SW, Calmar, AL 35053 • (256) 775-8280

AMERICAN TANK

