

Over and Above Estimate

Region: 2

Location: NY023

CSS #: 17732

Maximo Work Order No.: 3176

Asset#: NA

Date Issued: 2/26/19

Original Description: Repair both upper and lower entry key pads at the entrance to MEP lot.

Diagnosis: LoCurrent Systems is pleased to provide a quotation to replace the (3) existing nonfunctional AE-1000 Entry Units (Approx. 10-11 years old & discontinued) with (3) new Linear E3 Entry Units.

Non Pre-Priced Estimate:

Quantity	Line Item Number	Description	Labor Hours	Unit	Labor	Materials	Equipment	Total
1		Materials (See attached estimate for line items)				\$6,576.00		\$6,576.00

Note: RS Means (Pre-Priced) not used in compiling this estimate.

Note: Subcontractor quote attached.

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	Equipment Cost	Total Cost	CE Factor	Total Estimate
32 x \$75.00	\$2,400	\$6,576.00		\$8,976.00	90%	\$8,078.00

Please see attached estimate

Note:

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID: P. Totten, NY USARC

Date of Visit: 9/13/19

Building: Bldg 128 and Gates

CSS: 17732 Inv # 1501

Contractor Personnel on Site:

CMMS: _____

- Nick LoRusso
- Ken Stahl

Service Order:

Corrective Maintenance:

Service Order Work Performed:

Unit: Telephone Entry

Manufacturer: Linear

Model: AE 1000, AM-KP

Serial: _____

Description: Key pads not working on AE 1000's at Gate or main door at 128

Repairs: No Repair Possible at time of visit.
AE 1000 needs complete replacement.
AE 1000 no longer available, switch to
new version units and replace old
peripherals with new.

To be signed by the Contractor:

Print Name: Nick LoRusso Date: 9/13/19

Signed: MLR

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Loc Carbos AFOS Date: 9/13/19

Signed: Loc Carbos

E-Mail: Locais.A-Carbo.CTR@msn.com

LoCurrent Systems, LLC

3522 County Highway 11
 Cooperstown, NY 13326
 (607)293-7300
 locurrent@gmail.com



Estimate

ADDRESS

Jamie Merchant
 ISG International Support Group

ESTIMATE # 1434**DATE** 09/17/2019**P.O. NUMBER**

Ft. Totten NY (3) E3 EntryUnits

	ACTIVITY	QTY	AMOUNT
09/17/2019	Services CSS#17732 Ft. Totten, NY USARC Install (3) Linear E3 Entry Units (Follow Up Quotation to Inv#1501)	1	8,976.00

Dear Mr. Merchant:

As per your request, LoCurrent Systems is pleased to provide a quotation to replace the (3) existing nonfunctional AE-1000 Entry Units (Approx. 10-11 years old & discontinued) with (3) new Linear E3 Entry Units.

Cost Breakdown:

(3) Linear E3 Entry
Units.....\$6,476.00
Miscellaneous Fittings, Connectors & wire
etc.....\$100.00
Labor to install (2) men 16 hours @
\$75.....\$2,400.00

Grand
Total.....\$8,976.00

The cost for the above mentioned work is \$8,976.00.

If acceptable, please do not hesitate to contact us.

Thank you for thinking of LoCurrent Systems.

ACTIVITY	QTY	AMOUNT
Sincerely,		
Antonietta LoRusso		

	TOTAL	\$8,976.00
--	-------	-------------------

Accepted By

Accepted Date