

Over and Above Estimate

Region: 2

Location: NY023

CSS #: 94224

Maximo Work Order No. 23757

Asset#:

Date Issued: 07/6/2023

Original Description: Fix Leak coming from A/C unite in SIPR room of Building # 200

Description of Repairs: Fix leak coming from split AC unit in ceiling located on roof; unit will require evaporator to be cleaned; removal and replacement of condensate pump, charging of system with 4 lbs of R22 freon

Non Pre-Priced Estimate:

Quantity	Line Item #	Description	Labor Hours	Unit	Labor	Materials	Equipment	Total
1		Materials (See attached estimate for line items)				\$1155.00	\$	\$1155.00

Note: RS Means (Pre-Priced) not used in compiling this estimate.

Note: Subcontractor quote attached.

Estimate Summary:

Labor Hours	Labor Cost	Material	Equipment Cost	Total Cost	CE Factor	Total Estimate
(2 Men @ 6hrs/ea) 12 @ 210.00 = \$2520.00	\$2520.00	\$1155.00	\$	\$3675	1.02	\$3748.50

Please see attached estimate

ACAV SERVICES

July 18, 2023



ESTIMATE 071823 CSS94224 WO23757
PO100041055 (REPAIR)

Bill To		Ship To	
Customer	International Support Group M DUBOIS,	Recipient	99 RSC RD DPW L CORBO
Customer ID#	NY023 (BLDG 200)	Address	Ernie Pyle USARC BLDG 206 Ft Totten NY
Address	9050 Pines Blvd STE 150 Pembroke Pines FL 33024	Phone	718 631 6188
Phone	954 900 1095		
Payment Due	NET 30	Delivery Date	
Salesperson	JW	Shipping Method	N/A
Payment Terms	N/A	Shipping Terms	N/A

Qty.	Item#	Description	Unit Price	Line Total
		NY23 (BLDG 200) SIPR NET ROOM		
		FIX LEAK COMING FROM SPLIT AC UNIT IN CEILING EVAPORATOR LOCATED ON ROOF		
		UNIT WILL REQUIRE EVAPORATOR CLEANED NEW CONDENSATE PUMP CHARGE OF 4LBS FREON		

ACAV Services

11 Snug Cove Lane
Bayville NY 11709
Jacka377@verizon.net
516 941 6581

Qty.	Item#	Description	Unit Price	Line Total
		<u>MATERIAL</u>		
		1EA 208 VOLT CONDENSATE PUMP		\$415.00
		4 LBS R22 FREON @ \$185.00 PER LB		\$740.00
		TOTAL		\$1155.00
		<u>LABOR</u>		
		12 HRS @ \$210.00 PER HR		\$2520.00
		2 MEN 6 HRS EA		
		TOTAL		\$3675.00
			TOTAL	\$3675.00

