

Over and Above Estimate

Region: 2

Location: NY023

CSS #:31308

Maximo Work Order No. 2-13988 **Asset#:**

Date Issued: 06/24/2021-REQUOTE

Original Description: The contractor will replace 24 distribution handles at six (6) workstations with a total of four (4) at each station. Work proposed must be completed first to bring the system back to work mode to test and perform diagnostics for possible other repairs.

Description of Repairs: Diagnose and repair AMSA 12 fluid distribution system. Multiple hoses in the shop are inoperable, affecting the daily mission

Non Pre-Priced Estimate:

| Quantity | Line Item # | Description | Labor Hours | Unit | Labor | Materials | Equipment | Total |
|----------|-------------|--|-------------|------|-------|------------|-----------|----------|
| 1 | | Materials (See attached estimate for line items) | | | | \$13680.00 | \$ | 13680.00 |

Note: RS Means (Pre-Priced) not used in compiling this estimate.

Note: Subcontractor quote attached.

Estimate Summary:

| Labor Hours | Labor Cost | Material | Other cost | Total Cost | CE Factor | Total Estimate |
|--|------------|------------|------------|------------|-----------|----------------|
| X3 men at 1 days= Total man hours plus 250.00 Diagnostic cost | \$2290.00 | \$13680.00 | \$ | \$15970.00 | .90 | \$14373.00 |

Please see attached estimate.



RODON Home Improvement Inc.

2167 W9 St. Brooklyn, NY11223

T:(347)400-3735 e-mail:info@rodonusa.com

PROPOSAL

| | | | |
|---|------------|---|------------------------|
| PROPOSAL SUBMITTED TO Michele Dubois ISG 9050 Pines Blvd., Suite 150 Pembroke Pines, FL 33024 | | TODAY'S DATE 09.21.2022 | DATE OF PLANS/PAGE #'S |
| PHONE NUMBER | FAX NUMBER | JOB NAME Shop liquid handle replace | |
| ADDRESS, CITY, STATE, ZIP NY023. Fort Totten, NY. | | JOB LOCATION Repair shop | |

We propose hereby to furnish material and labor necessary for the completion of:

- Replace all 24 distribution handles at 6 work station (4 on each station)
- Test and diagnose the systems.

Material cost: \$13,680.00

1. 24 **WOLFLOBE** mod.#250251, @\$495 ea. = \$11,880.
2. 24 Hose swivel, Mod.#224457 @75 ea. = \$1,800.

Labor Cost : \$2,040.00 (3 guys, 8 hrs. x \$85/hr.)

Diagnose : \$250.00.

Total Cost: \$15,970.00

(I did check the entire lubrication systems with Mr. Louis, at Fort Totten.

Entire system is shut down.

All dispense handles are out of work.

We concluded that, in order to bring back to work mode the system, we need to check it one by one.

To do so, the entire system needs new handles to be installed first.

Attached is proposal for replacing liquid handles.)

We propose hereby to furnish material and labor – complete in accordance with above specifications for the sum of:

dollars (\$15,970.00

Payment as follows:

All material is guaranteed to be as specified. All work to be completed in a substantial workmanlike manner according to specifications submitted, per standard practices. Any alteration or deviation from above specifications involving extra costs will be executed only upon written orders, and will become an extra charge over and above the estimate. All agreements contingent upon strikes, accidents or delays beyond our control. Owner to carry fire, tornado and other necessary insurance. Our workers are fully covered by Workmen's Compensation Insurance. If either party commences legal action to enforce its rights pursuant to this agreement, the prevailing party in said legal action shall be entitled to recover its reasonable attorney's fees and costs of litigation relating to said legal action, as determined by a court of competent jurisdiction.

**Authorized
Signature**

Note: this proposal may be withdrawn by us if not accepted within 60 days.

ACCEPTANCE OF PROPOSAL The above prices, specifications and conditions are satisfactory and are hereby accepted. You are authorized to do the work as specified. Payment will be made as outlined above.

Signature

Signature _____

Date of Acceptance

