

ACAV SERVICES

September 14, 2022



ESTIMATE 091422 CSS89822 EMERGENCY REPAIR

Bill To		Ship To	
Customer	International Support Group M DUBOIS,	Recipient	99 RSC RD DPW L CORBO
Customer ID#	NY023 (BLDG 200)	Address	Ernie Pyle USARC BLDG 206 Ft Totten NY
Address	9050 Pines Blvd STE 150 Pembroke Pines FL 33024	Phone	718 631 6188
Phone	954 900 1095		
Payment Due	NET 30	Delivery Date	N/A
Salesperson	JW	Shipping Method	N/A
Payment Terms	N/A	Shipping Terms	N/A

Qty.	Item#	Description	Unit Price	Line Total
1	1	<p>NY23 BLDG 200 SEWER LIFT STATION</p> <p>LIFT STATION KEEPS SHUTTING DOWN</p> <p>EMERGENCY REPAIR TO REPLACE 2EA 60 AMP CIRCUIT BREAKERS</p> <p>REMOVE 1 PUMP AND CLEAR BLOCKAGE</p> <p><u>LABOR (EMERGENCY)</u></p> <p>8 HRS 2 \$250.00</p> <p><u>MATERIAL</u></p> <p>2EA 60 AMP BREAKERS</p>		\$2000.00

ACAV Services

11 Snug Cove Lane
Bayville NY 11709
Jacka377@verizon.net
516 941 6581

Qty.	Item#	Description	Unit Price	Line Total
		TOTAL		\$2080.00
		NOTE THE SEWER PIT IS FILLED WITH DEBRIS AND SHOULD BE PUMPED AND CLEANED		

TOTAL \$2080.00





Additional Funding Request

Site: NY023	WO# 19231 CSS # 89822
Description of Repairs	CNTR responded to an emergency call. Onsite had to make an emergency repair to replace two 60amp circuit breakers that kept tripping and remove and clear blockage prohibiting the water to pump properly. Heavy rains in area
Diagnosis: Initial Work Order	Troubleshoot/repair Lift pump
Explanation of Additional Costs for Repairs	
Additional Labor Costs to Perform Repairs	8 Hours @ 250.00 = \$2000.00
Additional Material Cost to Perform Repairs	80.00
Total Cost of Repair	\$2080.00