

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY023 - 123

Date of Visit: 12/7/22

Location Address: Fort Totten

Contractor Personnel on Site:

Deen Row

Work Performed: g Unit heater manually turned off, HV unit thermostat set to Turned on unit heater manually. Adjusted HV unit thermostat, Now room has heat.
Service Calls - PO/CSS#

91091

Please take pictures and send with quote

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Deen Vaughn Row

Date: 12/7/22

Signed: Deen Vaughn Row

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site.

Print Name/Rank: P CORN 20

Date: 12-7-22

Signed: P CORN 20

Email: PETER.D.CORNISH.CORP@ARMY.MIL

